



170008222878



(2017)国认监认字(347)号



中国认可  
国际互认  
检测  
TESTING  
CNAS L1020



实验室名称：国家电器产品质量监督检验中心

Lab Name: China National Center for Quality Supervision  
and Test of Electrical Apparatus Products

No 18N0698-S

# 型式试验报告 Type Test Report

委托单位：江西变电设备有限公司

Client:

产品名称：干式变压器

Name of Product:

产品型号：SCB12-800/35

Product Type:

检验类别：委托试验

Test Category:

本实验室对出具的检验（试验）结果负责，未经实验室书面同意，不得部分地复制本报告。

The laboratory is responsible for the inspection (Test) results. The report shall not be reproduced except in full, written approval of the laboratory.

## 国家电器产品质量监督检验中心

## 检 验 报 告

№: 18N0698-S

共 38 页 第 01 页

委托单位	江西变电设备有限公司	检验类别	委托试验
生产单位	江西变电设备有限公司	到样日期	2018年10月18日
产品名称	干式变压器	产品型号	SCB12-800/35
生产单位地址	江西省抚州市崇仁县工业园区	原编号或生产日期	20180017
检验日期	2018年10月22日至 2018年10月26日	送样数量	1台
检验项目	例行试验 型式试验 声级测定 短路承受能力试验	检验依据	GB/T1094.1—2013 GB/T1094.11—2007 GB/T10228—2015 JB/T10088—2016 委托书要求
检验结论	干式变压器（型号：SCB12-800/35）例行试验、型式试验、声级测定、短路承受能力试验的试验结果符合检验依据标准和委托书要求，样品上述试验合格。		
	签发日期：2018年11月02日 有效期五年 注：本结论仅对送试样品负责。		
备注	/		

编制：

孙厚瑜

校对：

王其

审核：

张

批准：

朱