



中国认可
国际互认
检测
TESTING
CNAS L1020



实验室名称：国家电器产品质量监督检验中心

Lab Name: China National Center for Quality Supervision
and Test of Electrical Apparatus Products

No 20XB0391-S

型式试验报告

Type Test Report

委托单位：江西变电设备有限公司

Client:

产品名称：预装式变电站（华变）

Name of Product:

产品型号：RYBH-37/0.69-3150

Product Type:

检验类别：型式试验

Test Category:

本实验室对出具的检验（试验）结果负责，未经实验室书面同意，不得部分地复制本报告。

The laboratory is responsible for the inspection (Test) results. The report shall not be reproduced except in full, written approval of the laboratory.

国家电器产品质量监督检验中心

检 验 报 告

No: 20XB0391-S

共 82 页 第 01 页

委托单位	江西变电设备有限公司	检验类别	型式试验
生产单位	江西变电设备有限公司	到样日期	2020年09月22日
产品名称	预装式变电站（华变）	产品型号	RYBH-37/0.69-3150
生产单位地址	江西省抚州市崇仁县工业园区	原编号或生产日期	BD202009-602
检验日期	2020年09月26日至 2021年03月16日	送样数量	1台
检验项目	出厂试验 强制的型式试验（不包括辅助和控制回路的附加试验） 验证预装式变电站声级的试验设计和外观检查 机械寿命试验前机械特性测量和机械操作试验 机械寿命试验 额定短路电流的关合和开断试验 额定转移电流的开断试验 盐雾试验	检验依据	GB/T17467—2020 DL/T537—2018 委托书要求
检验结论	<p>预装式变电站（华变）（型号：RYBH-37/0.69-3150）出厂试验、强制的型式试验（不包括辅助和控制回路的附加试验）、验证预装式变电站声级的试验、设计和外观检查、机械寿命试验前机械特性测量和机械操作试验、机械寿命试验、额定短路电流的关合和开断试验、额定转移电流的开断试验、盐雾试验的试验结果符合检验依据标准和委托书要求，样品上述试验合格。</p> <p style="text-align: right;">签发日期：2021年03月16日 有效期八年</p> <p>注：本结论仅对送试样品负责。</p>		
备注	/		

编制：

张川

校对：

李乐

审核：

张

批准：

李明智